


CERTIFICATE

Certified Passive House Component

Component-ID 1732ed03 valid until 31st December 2023

Passive House Institute
Dr. Wolfgang Feist
64283 Darmstadt
Germany



Category: **Entry door (opaque)**

Manufacturer: **SC Danprod SRL
Targu Ocna
Romania**


Product name: **Husky Clima 93**

This certificate was awarded based on the following criteria for the cool, temperate climate zone

Comfort $U_D = 0.80 \leq 0.80 \text{ W}/(\text{m}^2 \cdot \text{K})$
 $U_{D,\text{installed}} \leq 0.85 \text{ W}/(\text{m}^2 \cdot \text{K})$
with $U_{\text{door leaf}}^1 = 0.43 \text{ W}/(\text{m}^2 \cdot \text{K})$

Hygiene $f_{Rsi=0.25} \geq 0.70$

Airtightness $Q_{100} = 0.9 \leq 2.25 \text{ m}^3/(\text{h} \cdot \text{m})$



(Inward opening)

¹U-value of the insulated area of door leaf

cool, temperate climate



**CERTIFIED
COMPONENT**

Passive House Institute